

ANALYTICAL RESULTS

Client Sample ID		HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date		03/10/2024 07:15:00 AM	03/10/2024 07:30:00 AM	03/10/2024 07:50:00 AM					
Sample Number		L24084125	L24084126	L24084127					
CHEMISTRY									
WC17NS : Biochemical oxygen demand									
BOD5	mg/L	81	<2	<2					
Date of Performance	DD/MM/YY	05/10/24	05/10/24	05/10/24					
WC26NS500 : Oil & Grease									
Oil & Grease	mg/L	-	<5	<5					
Date of Performance	DD/MM/YY		09/10/24	09/10/24					
WC34MET : pH in Water									
pH	pH units	-	-	7.2					
Date of Performance	DD/MM/YY			04/10/24					
WC44NS : Total, Fixed & Volatile Suspended Solids									
Total Suspended Solids	mg/L	-	<2	9					
Date of Performance	DD/MM/YY		09/10/24	09/10/24					

"-" = Not required or refer to Laboratory comment

Client Sample ID	HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date	03/10/2024 07:15:00 AM	03/10/2024 07:30:00 AM	03/10/2024 07:50:00 AM					
Sample Number	L24084125	L24084126	L24084127					
MICRO								
MI28 : Total Coliforms and/or E.coli by Enzyme Substrate Method								
Total Coliforms	Orgs / 100mL	-	<1	31				
E.coli	Orgs / 100mL	-	<1	5				
Date of Performance	D/M/Y H:M		04/10/24 10:47	04/10/24 10:47				
NUTRIENTS								
NU102 : Total Nitrogen & Total Phosphorus								
Total Nitrogen	mg/L	-	-	2.07				
Total Phosphorus	mg/L	-	-	0.130				
Date of Performance	DD/MM/YY			10/10/24				
NU40 : Ammonia - Nitrogen								
Ammonia NH3 -N Low Level	mg/L	-	<0.01	0.01				
Date of Performance	DD/MM/YY		10/10/24	10/10/24				

"-" = Not required or refer to Laboratory comment