

ANALYTICAL RESULTS

Client Sample ID		HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date		12/11/2024 08:30:00 AM	12/11/2024 09:00:00 AM	12/11/2024 08:50:00 AM					
Sample Number		L24095491	L24095492	L24095493					
CHEMISTRY									
WC17NS : Biochemical oxygen demand									
BOD5	mg/L	150	<2	<2					
Date of Performance	DD/MM/YY	14/11/24	14/11/24	15/11/24					
WC26NS500 : Oil & Grease									
Oil & Grease	mg/L	-	<5	<5					
Date of Performance	DD/MM/YY		14/11/24	14/11/24					
WC34MET : pH in Water									
pH	pH units	-	-	7.3					
Date of Performance	DD/MM/YY			13/11/24					
WC44NS : Total, Fixed & Volatile Suspended Solids									
Total Suspended Solids	mg/L	-	<2	10					
Date of Performance	DD/MM/YY		18/11/24	18/11/24					

"-" = Not required or refer to Laboratory comment

Client Sample ID	HEAD OF WORKS	#1 RWDT	#2 LICENCE DISCH					
Sampled Date	12/11/2024 08:30:00 AM	12/11/2024 09:00:00 AM	12/11/2024 08:50:00 AM					
Sample Number	L24095491	L24095492	L24095493					
MICRO								
MI28 : Total Coliforms and/or E.coli by Enzyme Substrate Method								
Total Coliforms	Orgs / 100mL	-	<1	180				
E.coli	Orgs / 100mL	-	<1	43				
Date of Performance	D/M/Y H:M		13/11/24 08:34	13/11/24 08:34				
NUTRIENTS								
NU102 : Total Nitrogen & Total Phosphorus								
Total Nitrogen	mg/L	-	-	1.81				
Total Phosphorus	mg/L	-	-	0.092				
Date of Performance	DD/MM/YY			14/11/24				
NU40 : Ammonia - Nitrogen								
Ammonia NH3 -N Low Level	mg/L	-	<0.01	0.01				
Date of Performance	DD/MM/YY		14/11/24	14/11/24				

"-" = Not required or refer to Laboratory comment